



# Certificate of Calibration

Calibration of thermometer  
In-house method

Certificate No.: 20CA02120901 03A Date of issue: 11-Dec-2020 Page: 1 of 1

### Item tested

Description \*: High Accuracy Wifi Temperature & Humidity Data Logger Sensor

Manufacturer \*: LASCAR Model/Type\*: EL-WIFI-TH+

Equipment No. \*: 988BAD20F1D8 Resolution \*: 0.01°C

Location of the test 10/F Yick Fung Group Building, 2 Kin Wong Street, Tuen Mun, N.T., Hong Kong

### Item submitted by

Customer \*: Lascar Electronics (HK) Limited

Address. \*: 8th Floor, China Aerospace Centre, 143 Hoi Bun Road, Kwun Tong.

Date of request: 08-Dec-2020

Date of Calibration: 10-Dec-2020

### Apparatus used

Description:	Serial No. / Equip. No.:	Expire Date
Temp / Humidity Chamber	10710071/ MT-RF-022051	18-Apr-2022
Temp / Humidity Datalogger	AA-1804214/ MT-RF-020201	27-Apr-2021

### Ambient conditions

Temperature: 22±2 °C

Test specifications Calibration of thermometer at 15°C 23°C

### Test results

Calibration point	Correction to the UUT	Expanded uncertainty
15	-0.06	0.20
23	0.05	0.20

Unit: °C

### Remark:

- 1 Immersion Depth: Full
- 2 The expanded uncertainty is based on standard uncertainty multiplied by coverage factor k=2, providing a level of confidence of approximately 95%.
- 3 The temperature quoted refer to International Temperature Scale of 1990 (ITS-90).
- 4 The results reported in this certificate refer to the condition of the instrument on the date of calibration and carry no implication regarding the long-term stability of the instrument.
- 5 \* Denote information supplied by customer
- 6 The unit under test (UUT) was allowed to stabilized in the laboratory for 24 hours before commencement of calibration

-END-

Approved Signatory:

Huang Jianmin



### Certificate of Calibration

Calibration of Relative Humidity measurement device  
In-house method

Certificate No.: 20CA02120901 03B      Date of issue: 11-Dec-2020      Page: 1 of 1

#### Item tested

Description\*: Wifi Temperature & Humidity Data Logger Sensor  
Manufacturer\*: LASCAR      Model/Type \*: EL-WIFI-TH+  
Equipment No.\*: 988BAD20F1D8      Resolution\*: 0.1%

Location of the test 10/F Yick Fung Group Building, 2 Kin Wong Street, Tuen Mun, N.T., Hong Kong

#### Item submitted by

Customer\*: Lascar Electronics (HK) Limited  
Address\*: 8th Floor, China Aerospace Centre, 143 Hoi Bun Road, Kwun Tong.  
Date of request: 08-Dec-2020

Date of Calibration: 10-Dec-2020

#### Apparatus used

Description:	Serial No./ Equip. No.:	Expire Date
Temp / Humidity Chamber	10710071/ MT-RF-022051	18-Apr-2022
Temp / Humidity Datalogger	AA-1804214/ MT-RF-020201	27-Apr-2021

#### Ambient conditions

Temperature: 22±2 °C

Test specifications Calibration of relative humidity measurement device at 40%, 75%.

#### Test results

Calibration point	Correction to the UUT	Expanded uncertainty	Unit: %
40	-0.9	3.0	
75	-0.7	3.0	

Temperature setting: 20 °C

#### Remark:

- The expanded uncertainty is based on standard uncertainty multiplied by coverage factor k=2, providing a level of confidence of approximately 95%
- The test conditions are the ambient temperature and relative humidity around the RH generator.
- This method is only suitable for working standards.
- The results reported in this certificate refer to the condition of the instrument on the date of calibration and carry no implication regarding the long-term stability of the instrument.
- \* Denote information supplied by customer
- The unit under test (UUT) was allowed to stabilize in the laboratory for 24 hours before commencement of calibration

-END-

Approved Signatory:

Huang Jianmin